

## LAFAYETTE WATER QUALITY ANALYSIS

2/25/2015

pH	7.3
Alkalinity	250 mg/L as CaCO <sub>3</sub>
Temperature	15.6 °C
Fluoride	0.24 mg/L
Orthophosphate	0.66 mg/L
Total phosphate	1.66 mg/L
Chloramines (combine)	0.94 mg/L
Calcium	220 mg/L as CaCO <sub>3</sub>
Lead	below detectable levels
Copper	0.336 mg/L
Iron	0.221 mg/L
Manganese	0.021 mg/L
Magnesium	160 mg/L CaCO <sub>3</sub>
Chlorides	13.06 mg/L
Sulfates	0.821 mg/L
Conductivity	680 µm HOS/cm
Total bacteria	0
Total hardness	380 mg/L as CaCO <sub>3</sub>
Grains of hardness	22 grains per gallon